

767-112AX-08

Bill No. CS/HB 705

Amendment No. \_\_\_\_ (for drafter's use only)

	<u>Senate</u>	CHAMBER ACTION	<u>House</u>
1		.	
2		.	
3		.	
4		.	

ORIGINAL STAMP BELOW

Representative(s) Harrell offered the following:

**Amendment (with title amendment)**

On page 6, between lines 18 and 19,

insert:

(15) Since monitoring is the exclusive mechanism for detecting contamination of Florida's underground sources of drinking water, no aquifer storage and recovery wells may be permitted until:

(a) The department has demonstrated that monitoring technologies are capable of detecting any fluid movement outside the zone of discharge. This demonstration shall be made through a written report provided to the President of the Senate and Speaker of the House of Representatives;

(b) The permit applicant has demonstrated to the department that its monitoring system is capable of detecting any fluid movement outside the zone of discharge within 48 hours of such movement and has demonstrated the absence of fractures, faults, fissures, and solution channels in the areas serving as confinement; and

767-112AX-08

Bill No. CS/HB 705

Amendment No. \_\_\_\_ (for drafter's use only)

1           (c) The Department of Health has demonstrated that  
 2 detection technologies are capable of determining the presence  
 3 of microbial contaminants, including bacteria, viruses, and  
 4 protozoa, in the injected water. This demonstration shall be  
 5 made through a written report provided to the President of the  
 6 Senate and Speaker of the House of Representatives.

7  
 8 The determinations and analyses required under this subsection  
 9 shall be completed by June 30, 2002.

10  
 11  
 12  
 13  
 14  
 15  
 16  
 17  
 18  
 19  
 20  
 21  
 22  
 23  
 24  
 25  
 26  
 27  
 28  
 29  
 30  
 31

===== T I T L E    A M E N D M E N T =====

And the title is amended as follows:

On page 1, line 19,

after the first semicolon, insert:

providing requirements relating to the  
monitoring and detection of contaminants;