

Amendment No. (for drafter's use only)

CHAMBER ACTION

Senate

House

.

---

1 Representative(s) Benson offered the following:

2  
3 **Amendment (with title amendment)**

4 Between lines 628 and 629, insert:

5  
6 Section 13. All new and replacement fire hydrants in this  
7 state shall have an internal hydrant valve device installed  
8 which will prevent intentional or accidental backflow  
9 contamination of the domestic water supply. Such device may in  
10 no way delay access to the water supply for fire protection.

11  
12  
13 ===== T I T L E A M E N D M E N T =====

14 Remove line 104 and insert:

Amendment No. (for drafter's use only)

16 | severability; prescribing requirements for fire hydrants to  
17 | prevent backflow contamination of the domestic water supply;  
18 | providing an effective date.