

Bill No. SB 1822

Barcode 200910

CHAMBER ACTION

Senate

House

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31

Comm: RCS
04/09/2007 06:09 PM

.
. .
. .
. .
. .
. .

The Committee on Banking and Insurance (Peaden) recommended
the following amendment:

Senate Amendment (with title amendment)

On page 5, between lines 12 and 13,

insert:

Section 3. Subsection (5) is added to section 509.211,
Florida Statutes, to read:

509.211 Safety regulations.--

(5) Every enclosure that has boilers or other
machinery generating carbon monoxide in a public lodging
establishment must be equipped with one or more carbon
monoxide sensor devices that bear the label of a nationally
recognized testing laboratory and that have been tested and
listed as complying with the most recent Underwriters
Laboratories, Inc., Standard 2034, or its equivalent, unless
it is determined that no potential carbon monoxide hazard
exists within the enclosure. Such devices shall be integrated
with the public lodging establishment's fire-detection system.
Any such installation or determination shall be made in

Bill No. SB 1822

Barcode 200910

1 accordance with rules adopted by the division.

2

3 (Redesignate subsequent sections.)

4

5

6 ===== T I T L E A M E N D M E N T =====

7 And the title is amended as follows:

8 On page 1, line 14, after the semicolon,

9

10 insert:

11 amending s. 509.211, F.S.; requiring that
12 certain public lodging establishments be
13 equipped with carbon monoxide sensor devices;

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31