

Bill No. CS for SB 404

Barcode 730390

	CHAMBER ACTION	
<u>Senate</u>		<u>House</u>

1	.
2	.
3	.
4	.
5	.
6	.
7	.
8	.
9	.
10	.

Floor: WD/2R  
03/28/2007 02:37 PM

11 Senator Baker moved the following amendment:

13 **Senate Amendment (with title amendment)**

14 On page 10, between lines 6 and 7,

16 insert:

17 Section 8. If an existing warehouse is expanded, the  
18 addition must comply with the requirements in chapter 9 of the  
19 Florida Building Code; however, the existing warehouse need  
20 not be updated to meet those requirements so long as it is in  
21 compliance with the Florida Building Code, 2001 edition, and  
22 with requirements concerning sprinkler systems in chapter 903  
23 of the Florida Building Code.

25 (Redesignate subsequent sections.)

28 ===== T I T L E A M E N D M E N T =====

29 And the title is amended as follows:

30 On page 3, line 2, after the semicolon,

31

Bill No. CS for SB 404

Barcode 730390

1 insert:

2           exempting certain existing warehouses from  
3           requirements in the Florida Building Code  
4           concerning fire protection under certain  
5           conditions;

6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31