

Amendment No.

CHAMBER ACTION

Senate

House

.



1 Representative Hutson offered the following:

2

3 **Substitute Amendment for Amendment (819455) (with title**  
4 **amendment)**

5 Remove line 540 and insert:

6 at least 10 years. The battery requirements of this section do  
7 not apply to a fire alarm, smoke detector, smoke alarm, or  
8 ancillary component that is electronically connected as part of  
9 a centrally monitored or supervised alarm system.

10

11



12

**T I T L E A M E N D M E N T**

13

Remove line 43 and insert:

799477

Approved For Filing: 4/24/2014 4:43:46 PM

Amendment No.

14 | by a certain date; providing applicability; amending  
15 | s. 553.993, F.S.; revising

799477

Approved For Filing: 4/24/2014 4:43:46 PM