

Amendment No.

CHAMBER ACTION

Senate

House

.

Representative Eagle offered the following:

Amendment to Amendment (868193) (with title amendment)

Remove line 489 of the amendment and insert:

at least 10 years. The battery requirements of this section do not apply to a fire alarm, smoke detector, smoke alarm, or ancillary component that is electronically connected to a system as part of a UL Listed centrally monitored fire alarm station.

T I T L E A M E N D M E N T

Remove lines 586-588 of the amendment and insert:

smoke alarms powered by a specified type of battery in certain circumstances; requiring use of such alarms by

364617

Approved For Filing: 4/23/2014 4:32:08 PM

Amendment No.

15 | a certain date; providing applicability; amending s.
16 | 553.993, F.S.; revising

364617

Approved For Filing: 4/23/2014 4:32:08 PM