

Amendment No.

CHAMBER ACTION

Senate

House

.

1 Representative Harrison offered the following:

2
3 **Amendment**

4 Remove lines 231-240 and insert:

5 d. An assisted living facility that is issued a building
6 permit or certificate of occupancy before July 1, 2016, may at
7 its option and after notifying the authority having
8 jurisdiction, remain under the provisions of the 1994 and 1995
9 editions of the National Fire Protection Association, Life
10 Safety Code, NFPA 101, and NFPA 101A. The facility opting to
11 remain under such provisions may make repairs, modernizations,
12 renovations, or additions to, or rehabilitate, the facility in
13 compliance with NFPA 101, 1994 edition, and may utilize the
14 alternative approaches to life safety in compliance with NFPA

311481

Approved For Filing: 2/22/2016 1:45:25 PM

Amendment No.

15 101A, 1995 edition. However, a facility for which a building
16 permit or certificate of occupancy is issued before July 1,
17 2016, that undergoes Level III building alteration or
18 rehabilitation, as defined in the Florida Building Code, or
19 seeks to utilize features not authorized under the 1994 or 1995
20 editions of the Life Safety Code must thereafter comply with all
21 aspects of the uniform firesafety standards established under s.
22 633.206, and the Florida Fire Prevention Code, in effect for
23 assisted living facilities as adopted by the State Fire Marshal.

311481

Approved For Filing: 2/22/2016 1:45:25 PM