



753100

LEGISLATIVE ACTION

Senate	.	House
Comm: RCS	.	
02/06/2018	.	
	.	
	.	
	.	

The Committee on Children, Families, and Elder Affairs (Broxson) recommended the following:

Senate Amendment (with title amendment)

Between lines 1480 and 1481

insert:

Section 44. Subsection (2) of section 633.314, Florida Statutes, is amended to read:

633.314 Sale or use of certain types of fire extinguishers prohibited; penalty.—

(2) It is unlawful for any person, directly or through an agent, to sell, offer for sale, or give in this state any make,



753100

11 type, or model of fire extinguisher, either new or used, unless
12 such make, type, or model of extinguisher has first been tested
13 and is currently approved or listed by Underwriters
14 Laboratories, Inc., Factory Mutual Laboratories, Inc., or
15 another testing laboratory recognized by the State Fire Marshal
16 as nationally recognized in accordance with procedures adopted
17 by rule, taking into account the laboratory's facilities,
18 procedures, use of nationally recognized standards, and any
19 other criteria reasonably calculated to reach an informed
20 determination, and unless such extinguisher carries an
21 Underwriters Laboratories, Inc., or manufacturer's serial
22 number. Such serial number must ~~shall~~ be permanently affixed
23 ~~stamped~~ on the manufacturer's identification and instruction
24 plate.

25
26 ===== T I T L E A M E N D M E N T =====

27 And the title is amended as follows:

28 Between lines 170 and 171

29 insert:

30 s. 633.314, F.S.; requiring that serial numbers be
31 permanently affixed, rather than permanently stamped,
32 on certain plates of fire extinguishers; amending