

Amendment No. 1.

COMMITTEE/SUBCOMMITTEE ACTION

ADOPTED	<u> </u>	(Y/N)
ADOPTED AS AMENDED	<u> </u>	(Y/N)
ADOPTED W/O OBJECTION	<u> </u>	(Y/N)
FAILED TO ADOPT	<u> </u>	(Y/N)
WITHDRAWN	<u> </u>	(Y/N)
OTHER	<u> </u>	

1 Committee/Subcommittee hearing bill: Commerce Committee
 2 Representative Diaz, M. offered the following:

Amendment

5 Remove everything after the enacting clause and insert:
 6 Section 1. Subsection (20) is added to section 633.202,
 7 Florida Statutes, to read:

8 633.202 Florida Fire Prevention Code.—

9 (20) (a) In apartment occupancies with enclosed corridors
 10 served by interior or exterior exit stairs, doorstep refuse and
 11 recycling collection containers, which stand upright on their
 12 own and do not leak liquids when standing upright, must be
 13 allowed in exit access corridors when all of the following
 14 conditions exist:

15 1. The maximum doorstep refuse and recycling collection
 16 container size does not exceed 13 gallons.

Amendment No. 1.

17 2. Waste, which is in a doorstep refuse and recycling
18 collection container, is not placed in the exit access corridors
19 for single periods exceeding 5 hours.

20 3. Doorstep refuse and recycling collection containers do
21 not occupy the exit access corridors for single periods
22 exceeding 12 hours.

23 4. Doorstep refuse and recycling collection containers do
24 not reduce the means of egress width below that required under
25 NFPA Life Safety Code 101:31, as adopted under the Florida Fire
26 Prevention Code.

27 5. Management staff have written policies and procedures
28 in place and enforce them to ensure compliance with this
29 subsection, and, upon request, provide a copy of such policies
30 and procedures to the authority having jurisdiction.

31 (b) In apartment occupancies with open-air corridors or
32 balconies served by exterior exit stairs, doorstep refuse and
33 recycling collection containers, which stand upright on their
34 own and do not leak liquids when standing upright, must be
35 allowed in exit access corridors when all of the following
36 conditions exist:

37 1. The maximum doorstep refuse and recycling collection
38 container size does not exceed 27 gallons.

39 2. Waste, which is in a doorstep refuse and recycling
40 collection container, is not placed in the exit access corridors
41 for single periods exceeding 5 hours.

Amendment No. 1.

42 3. Doorstep refuse and recycling collection containers do
43 not reduce the means of egress width below that required under
44 NFPA Life Safety Code 101:31, as adopted under the Florida Fire
45 Prevention Code.

46 4. Management staff have written policies and procedures
47 in place and enforce them to ensure compliance with this
48 subsection, and, upon request, provide a copy of such policies
49 and procedures to the authority having jurisdiction.

50 (c) The authority having jurisdiction may approve
51 alternative containers and storage arrangements that are
52 demonstrated to provide an equivalent level of safety to that
53 provided under paragraphs (a) and (b).

54 (d) The authority having jurisdiction shall allow
55 apartment occupancies a phase-in period until December 31, 2020,
56 to comply with this subsection.

57 (e) This subsection is repealed on July 1, 2021.

58 Section 2. This act shall take effect July 1, 2018.