

Amendment No. 1

COMMITTEE/SUBCOMMITTEE ACTION

ADOPTED	___	(Y/N)
ADOPTED AS AMENDED	___	(Y/N)
ADOPTED W/O OBJECTION	___	(Y/N)
FAILED TO ADOPT	___	(Y/N)
WITHDRAWN	___	(Y/N)
OTHER	_____	

1 Committee/Subcommittee hearing bill: Commerce Committee
2 Representative Botana offered the following:

3
4 **Amendment**

5 Remove lines 20-44 and insert:

6 Section 1. Subsection (18) of section 633.202, Florida
7 Statutes, is amended to read:

8 633.202 Florida Fire Prevention Code.—

9 (18) The authority having jurisdiction shall determine the
10 minimum radio signal strength for fire department communications
11 in all new high-rise and existing high-rise buildings. Two-way
12 radio communication enhancement systems may be used to comply
13 with minimum radio signal strength requirements. However, two-
14 way radio communication enhancement systems and similar systems
15 shall not be required in apartments or buildings that are four
16 stories or less in height. Existing buildings are not required

Amendment No. 1

17 | to comply with minimum radio strength for fire department
18 | communications and two-way radio system enhancement
19 | communications as required by the Florida Fire Prevention Code
20 | until January 1, 2025 ~~2022~~. However, by December 31, 2024 ~~2019~~,
21 | an existing building that is not in compliance with the
22 | requirements for minimum radio strength for fire department
23 | communications must apply for an appropriate permit for the
24 | required installation with the local government agency having
25 | jurisdiction and must demonstrate that the building will become
26 | compliant by January 1, 2027 ~~2022~~. Existing apartment buildings
27 | are not required to comply until January 1, 2030 ~~2025~~. However,
28 | existing apartment buildings are required to apply for the
29 | appropriate permit for the required communications installation
30 | by December 31, 2027 ~~2022~~.